




SWEDISH TECHNICAL APPROVAL

0226/06

and decision on production control in accordance with 18-20 § Law (1994:847) on technical specification requirements for construction works etc. BVL

Floor gully, Purus Line Vinyl


Holder	Purus AB, Södra Dragongatan 15, 271 39 Ystad. Tel: 010-414 49 00, fax: 010-414 49 96, e-mail: info@purus.se Internet: www.purus.se VAT number: 556361-1887.	
Product	Floor gully Purus Line Vinyl are made of PP and channel/grid are made of stainless steel. Purus Line Vinyl is designed with vertical or horizontal outlet in Ø50 mm or Ø75 mm.	
Intended use	Purus Line Vinyl are intended for domestic waste water and for installation in concrete or timber floor constructions with plastic or clinker surface.	
Trade name	Purus Line Vinyl.	
Approval	The products satisfy the requirements set forth in 2 § 3 BVL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of the Building Regulations issued by the National Board of Housing, Building and Planning (<i>BBR</i>):	
	Waste water installations Design	6:641, 1:st and 2:nd paragraph 6:644, 1:st sentence and 2:nd paragraph
	Floor gully shall be able to drain at least 150 % of the water flow from outlets.	
Associated documents	Installation instruction Purus Line with vinyl covering, dated 2011-03. Installation instruction Purus Line with clinker covering, dated 2009-09. Maintenance of Purus floor gullies, dated 2009-04.	

Control	<p>Production control is to be performed in accordance with instructions for control dated 2007-02-22 and with registration number 210-97-0648. An independent inspection body, SP Technical Research Institute of Sweden, audits the control.</p> <p>When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with the requirements stated in the approval and the associated documents. He must also check that the product is accompanied by a manufacturing assurance, which certifies that the product has been manufactured in accordance with the documents on which this certificate is based.</p>																
Manufacturer	<p>Production control includes the following sites: Purus AB, Södra Dragongatan 15, 271 39 Ystad. Purus AB, Hasselgatan 25, 333 32 Smålandsstenar.</p>																
Marking	<p>The products are to be marked at the factory. The marking consists of a text on every product and packing supplied and includes:</p> <p><u>Product and packing are marked with:</u></p> <table> <tr> <td>Approval holder</td><td>Purus</td></tr> <tr> <td>Product type designation</td><td>Name</td></tr> <tr> <td>Product code/RSK-nr.</td><td>Number</td></tr> <tr> <td>Boverket's registered trademark</td><td></td></tr> <tr> <td>Certification body and accreditation number</td><td>SP SITAC 1002</td></tr> <tr> <td>Inspection body</td><td>SP</td></tr> </table> <p><u>Products are also marked with:</u></p> <table> <tr> <td>Approval number</td><td>0226/06</td></tr> <tr> <td>Consecutive manufacture date of production</td><td>Year/month</td></tr> </table>	Approval holder	Purus	Product type designation	Name	Product code/RSK-nr.	Number	Boverket's registered trademark		Certification body and accreditation number	SP SITAC 1002	Inspection body	SP	Approval number	0226/06	Consecutive manufacture date of production	Year/month
Approval holder	Purus																
Product type designation	Name																
Product code/RSK-nr.	Number																
Boverket's registered trademark																	
Certification body and accreditation number	SP SITAC 1002																
Inspection body	SP																
Approval number	0226/06																
Consecutive manufacture date of production	Year/month																
Basis for approval	<p>Report ETk P6 02181 from SP Technical Research Institute of Sweden. Drawing list from SP SITAC dated 2011-03-21 Production control P9 01641-10 from SP.</p>																
Comments	<p>Installation instructions shall be delivered in each package. Those floor gullies are approved according to standard SS-EN1253-1:2003. The removeable water trap needs to be cleaned regularly.</p> <p>This approval supersedes previous certificate with same number and reg. no. T600226-03 dated 2008-12-18.</p>																

Period of
validity

This approval is valid until 2016-03-30.

The formal validity of an approval expires after the transitional period for the harmonised specification that makes it possible to CE-mark the product. However, the technical assessment showing that the product fulfils the requirements in the building regulations, issued by the Swedish National Board of Housing, Building and Planning, is not affected.



Håkan Thiman



Marcus Tillman