

SWEDISH TECHNICAL APPROVAL

SC0265-10

and decision on production control in accordance with chapter 8, 22 and 23 §§ Planning and Building Act (2010:90), PBL

Floor gully, Purus Line/Corner

Holder	Purus AB, Södra Dragongatan 15, 271 39 Ystad. Tel: 010-414 49 00, fax: 010-414 49 96, e-mail: info@purus.se Internet: www.purus.se VAT number: 556361-1887.				
Product	Purus Line/Corner, floor gully made of PP with grating and upper part made of stainless steel. Purus Line/Corner has vertical or horizontal outlet in dimension 75 mm. Gully is also available in a low model with vertical or horizontal outlet in dimension 50 mm.				
Intended use	Gullies are intended for domestic waste water and for installation in concrete or timber floor constructions with ceramic tiles surface.				
Trade name	Purus Line/Corner.				
Approval	The product satisfy the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of the Building Regulations issued by the National Board of Housing, Building and Planning (BBR): <table><tr><td>Waste water installations</td><td>6:641, 1:st and 2:nd paragraph</td></tr><tr><td>Design</td><td>6:644, 1:st sentence and 2:nd paragraph, 1:st sentence</td></tr></table>	Waste water installations	6:641, 1:st and 2:nd paragraph	Design	6:644, 1:st sentence and 2:nd paragraph, 1:st sentence
Waste water installations	6:641, 1:st and 2:nd paragraph				
Design	6:644, 1:st sentence and 2:nd paragraph, 1:st sentence				
Associated documents	Installation instructions Purus Line – Twist, marked 21123 – 2012:1. Installation instructions Purus Corner – Twist, marked 21121 – 2012:1.				
Control	Production control is to be performed in accordance with instructions for control dated 2007-02-22 with registration number 210-97-0648. An independent inspection body audits the control, SP Technical Research Institute of Sweden.				

When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with the requirements stated in the approval and the associated documents. He must also check that the product is accompanied by a manufacturing assurance, which certifies that the product has been manufactured in accordance with the documents on which this certificate is based.



Manufacturer Production control includes the following sites:
Purus AB, Södra Dragongatan 15, 271 39 Ystad.
Purus AB, Hasselgatan 25, 333 32 Smålandsstenar.

Marking The products are to be marked at the factory.
The marking consists of a text on every product and packaging supplied and includes:

Products are marked with:

Approval holder
Consecutive production year/month

Purus
year/month

Packing are marked with:

Approval holder
Boverket's registered trademark
Certification body and accreditation number
Product type designation
Product code
Approval number
Inspection body

Purus
+
SP SITAC 1002
Purus Line/Corner
RSK-no.
SC0265-10
SP

Basis for approval Report P908196-B.
Drawing list created by SP SITAC 2010-06-29.

Comments Installation instructions shall be delivered in each package.

Floor gullies are approved according to standard SS-EN 1253-1:2003.
Low models fullfill requirements to receive discharge from a single shower head.

The removable water trap needs to be cleaned regularly.

Period of validity This approval is valid until 2015-06-30.

The formal validity of an approval expires after the transitional period for the harmonised specification that makes it possible to CE-mark the product. However, the technical assessment showing that the product fulfils the requirements in the building regulations, issued by the Swedish National Board of Housing, Building and Planning, is not affected.


Ingvar Pettersson


Marcus Tillman